

State of California
Department of Public Health
Water Treatment Device
Certificate Number
09 - 1942

Date Issued: January 28, 2009

Trademark/Model Designation

LC

LC Cooler

Replacement Elements

C-LC

C-LC

Manufacturer: Cuno Inc. a 3M company

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts

Inorganic/Radiological Contaminants

Lead

Organic Contaminants

None

Rated Service Capacity: 750 gal

Rated Service Flow: 0.75 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

